

Romulus Town Board Meeting

Water & Sewer District Reports

Date: October 21, 2020

To: Romulus Town Board

- ❖ Willard Water District – September daily average – 21,166 gallons
- ❖ Romulus Water District – September daily average – 21,166 gallons
- ❖ Rt. 89 Water District – September daily average – 6,013 gallons
- ❖ Water testing – currently all sample draws are up to date in all districts
- ❖ NYSDOH monthly reports – all DOH reports for all districts have been completed and sent to Seneca County Health Services
- ❖ Water meter readings – all water meters have been read for October - bills have been sent out
- ❖ Romulus Water District new water service installation – Dan Schrader 1914 Seneca Street
- ❖ Romulus Water District – installed new fire hydrant at Main and Seneca Street, added 2' extension, repaired under drains and restored lawn
- ❖ Willard Water District main leaks - 1 1515 Main St. 7/31/20 installed repair band
- ❖ Willard Water District service repair - 1 1543 Main St installed new box and rod
- ❖ Rt. 89 Water District – extended water service line to property line 5715 Rt 89, installed water service tap at 6215 Poplar Beach Rd (original tap was placed on neighbor's property), over all update – 90 applications submitted, 2 applications on hold for roadway repair, 85 site survey completed, 78 total active services

Respectfully submitted,

Hobie Stapleton

District Maintainer