

Romulus Town Board Meeting

Water & Sewer District Reports

Date: December 16, 2020

To: Romulus Town Board

- ❖ Willard Water District – November daily average – 19,100 gallons
- ❖ Romulus Water District – November daily average – 21,016 gallons
- ❖ Rt. 89 Water District – November daily average – 10,250 gallons
- ❖ Water testing – 4th quarter Willard THM sample results were good, THM's dropped below the state MCL level, will continue quarterly sampling, currently all sample draws are up to date in all districts
- ❖ DOH Annual Inspection – Seneca County Health Services conducted inspection on all districts, all went well, waiting on written report
- ❖ NYSDOH monthly reports – all November's DOH reports for all districts have been completed and sent to Seneca County Health Services
- ❖ New water district shed was delivered and all items have been moved in to shed, Westervelt Electric hooked up power and installed lights, A-Verdi storage container has been returned
- ❖ Willard Water District main leak – 1, 1427 Main St. (12/15/20) installed repair band
- ❖ Rt. 89 Water District main leak – 1, 6214 Poplar Beach Rd. (11/27/20) Service line came out of corporation stop on water main, appears the compression ring was missing, installed new compression ring and small piece of service line

Respectfully submitted,

Hobie Stapleton

District Maintainer