

Romulus Town Board Meeting

Water & Sewer District Reports

Date: January 20, 2021

To: Romulus Town Board

- ❖ Willard Water District – December daily average – 23,354 gallons
- ❖ Romulus Water District – December daily average – 26,398 gallons
- ❖ Rt. 89 Water District – December daily average – 7,174 gallons
- ❖ Water testing – currently all sample draws are up to date in all districts
- ❖ DOH Annual Inspection – Seneca County Health Services conducted the annual inspection on all districts, all went well, see written report
- ❖ NYSDOH monthly reports – all December's DOH reports for all districts have been completed and sent to Seneca County Health Services
- ❖ Water meter readings – all January meter readings have been completed in all districts and bills have been sent out
- ❖ Romulus Water District main leak – 1, 1968 Seneca Street, leaked showed up on the Romulus side of Seneca Street, it was determined the leak was the main service for Russel Rd., Town of Varick Water District was notified and Waterloo Water Department was called to repair leak
- ❖ Service Line, Water Shut Off Repair – 2 1974 & 1976 Seneca Street Romulus, installed box and rod
- ❖ Main line valve repair – Main Street and Seneca Street Romulus, installed new packing bolts and tighten down packing

Respectfully submitted,

Hobie Stapleton

District Maintainer