

Romulus Town Board Meeting

Water & Sewer District Reports

Meeting Date: April 20, 2022

Report Date: April 15, 2022

To: Romulus Town Board

- ❖ Willard Water District – March daily average – 18,419 gallons
- ❖ Romulus Water District – March daily average – 18,530 gallons
- ❖ Rt. 89 Water District – March daily average – 4,996 gallons
- ❖ Water testing – currently all sample draws are up to date in all water districts
- ❖ NYSDOH monthly reports – March DOH reports for all districts (Willard DTC, Willard, Romulus & Rt. 89) completed and sent to Seneca County Health Services
- ❖ U-DIG NY tickets – Regular tickets - 3 Emergency - 1
- ❖ Water meters – all meter readings completed; all bills are mailed out for the billing quarter; we completed training on the new Neptune water meter reading system
- ❖ Willard Water Treatment Plant – training and orientation is on going with DOC's employee Ethan Licak, updated billing account with Slack Chemicals, DOC's is working on a key setup for the water treatment plant and lakeshore pump station, Slack Chemical Company – reviewed all chemical dosing with the filter units, adjusted polymer dosing, will start monitoring water alkalinity and will be starting up potassium permanganate intake injection this week
- ❖ Willard Water District – repaired master water meter driveway on CR 132, Cleaned up stone pile, removed soils pile and repaired water main leak location Main St
- ❖ Rt. 89 Water District – completed two rounds of system flushing, with more flushing scheduled
- ❖ Training – Attended Finger Lakes Water Works Training Conference

Respectfully submitted,

Hobie Stapleton

Water Superintendent