

Romulus Town Board Meeting

Water & Sewer District Reports

Meeting Date: May 18, 2022

Report Date: May 13, 2022

To: Romulus Town Board

- ❖ Willard Water District – April daily average – 17,866 gallons
- ❖ Romulus Water District – April daily average – 17,675 gallons
- ❖ Rt. 89 Water District – April daily average – 4,010 gallons
- ❖ Water testing – currently all sample draws are up to date in all water districts
- ❖ NYSDOH monthly reports – April DOH reports for all districts (Willard DTC, Willard, Romulus & Rt. 89) completed and sent to Seneca County Health Services
- ❖ U-DIG NY tickets – Regular tickets - 7
- ❖ Service calls - 2 frozen meter 2014 Locust St. Romulus, and 6946 NY Rt 96a Willard, new owner, relocate meter
- ❖ Water meter change out – 1 6950 NY Rt 96a Willard
- ❖ Willard Water Treatment Plant – training is ongoing, WTP entrance key has been taken care of for access to plant, 2nd High lift pump and VFD to elevated storage tank is currently up and running on manual only, VFD is having issues working with the SCADA system at the plant, DOCCS will be contacting SCADA integrators, Hach Company - Partnership needs to be renewed with the town this year, the partnership covers all instrumentation at the water treatment plant and for field service, The partnership covers field service includes all parts, labor and travel for on-site repairs, preventive maintenance visits and instrument calibrations, Sump pump - stopped working at the plant – installed new pump, all in good working order, Water heater – started leaking at the plant, All Pro Plumbing the schedule to replace water heater soon
- ❖ Romulus Water District – Seneca County water district has installed a new master water meter that serves the Hamlet of Romulus, will be installing the new remote telemetry unit as soon as the new meter enclosure is completed
- ❖ Training – completed training with NYSDOH on the new Lead & Copper Rule Revisions – Lead Service Line Inventory Training

Respectfully submitted,

Hobie Stapleton - Water Department Superintendent

