

# ***Romulus Town Board Meeting***

## ***Water & Sewer District Reports***

**Meeting Date: June 15, 2022**

**Report Date: June 10, 2022**

### **To: Romulus Town Board**

- ❖ Willard Water District – May daily average – 23,451 gallons
- ❖ Romulus Water District – May daily average – 34,945 gallons
- ❖ Rt. 89 Water District – May daily average – 6,300 gallons
- ❖ Water testing – currently all sample draws are up to date in all water districts
- ❖ NYSDOH monthly reports – May DOH reports for all districts (Willard DTC WTP, Willard Hamlet W.D., Romulus Hamlet W.D. & Rt. 89 W.D.) were completed and sent to Seneca County Health Services
- ❖ U-DIG NY tickets – Regular tickets - 6
- ❖ 2021 Annual Water Quality Report - All AWQRs have been completed for all districts and have been placed on the town website for public view, AWQR Water customer notice will be placed on the July water bill
- ❖ Neptune Water Meter Reading System – the system was updated, and the mapping system is now working properly, Morgan is updating a few customers longitude and latitude locations, we both completed Neptune meter reader training with Ti-Sales, the system is in good working order
- ❖ Amish Water System – met with Henry E Beiler 5918 Rt 414 Romulus and requested site survey of the entire water system, all water outlet locations on the system, water line location for all of system, all property locations served by the water system and conduct chlorine surveillance sampling, as of 6/10/22 I've had No response on setting up the meeting will be checking with Henry again next week
- ❖ Willard Water Treatment Plant – 2<sup>nd</sup> High lift pump and VFD to elevated storage tank was repaired but will only run in manual mode (still waiting on the DOCCS to contact Team Work Integrators for repair), Hach Instruments– Aqua Logics installed 5 new turbidity reading instruments – all units are up and running in good order, Hach Partnership - needs to be renewed with the town this year, the partnership covers all instrumentation at the water treatment plant and for field service, the partnership covers all field service which includes all parts, labor and travel for on-site repairs, preventive maintenance visits and

instrument calibrations (X 4 yearly), Water heater – started leaking at the plant, waiting for All Pro Plumbing to schedule a date for replacement of water heater, Chemical Transfer Pump – pump was sporadically not working, new transfer pump was ordered and is in service

- ❖ Rt. 89 Water District – Water Service Requests – 2 Grant Kyle 6249 Rt. 89 & Amanda Schwartz 6208 Poplar Beach Rd., Water Service Installation – 1 Mary & Raymond Niles 6053 Lakeview Lane
- ❖ Training – Hobie attended the New York Rural Water Association Technical Training Workshop and Exhibition in Verona, NY

**Respectfully submitted,**

**Hobie Stapleton**

**Water Department Superintendent**