

Romulus Town Board Meeting

Water & Sewer District Reports

Date: July 20, 2022

To: Romulus Town Board

- ❖ Willard Water District – June daily average – 24,500 gallons
- ❖ Romulus Water District – June daily average – 37,110 gallons
- ❖ Rt. 89 Water District – June daily average – 6,770 gallons
- ❖ Willard WTP Total – June daily average – 183,360 gallons
- ❖ Willard DTC Campus – June daily average – 150,166 gallons
- ❖ Water testing – currently all sample draws are up to date in all water districts
- ❖ NYSDOH monthly reports – June’s DOH reports for all districts completed and sent to Seneca County Health Services
- ❖ U-DIG NY tickets – Regular tickets - 17 Emergency - 1
- ❖ Water meters – all water meters have been read for the second quarter and bills have been sent out
- ❖ Service Calls – 1 6962 1st Street Willard, leaking meter (frozen meter from winter), installed new meter
- ❖ Willard Water Treatment Plant – finished water transfer pump, I was informed DOCCS will be replacing this pump, request was originally denied, but now has been authorized, waiting on delivery and installation date – Weather Station, is now up and running, it can be found on the world wide web at Ambientweather.net, Hach partnership for instrumentation maintenance and calibration, account is all set up, Hach will be here first week of August, Supervisory Control And Data Acquisition (SCADA) system, Teamwork Solutions Integrators are scheduled to be here the first week of August to troubleshoot elevated tank pump control and to go over the SCADA system, WTP Tools, DOCCS removed all pipe wrenches, all adjustable wrenches, all Allen wrenches, all tee handle wrenches, all ratchet wrenches, all socket sets and the grease gun from the water treatment plant to be assigned to other facilities, replacement tools have either been delivered or on order, DVD water sample tap w/enclosure, will be installing a water sample tap to ensure proper sampling at DVD, WTP Water Heater, heater was replaced by All Pro Plumbing, all is in good working order
- ❖ Willard Water District – currently flushing the district

- ❖ Rt. 89 Water District – 6249 NY Rt. 89 - missing water service tap, it's been discovered that the water service tap cannot be located at this property, will be conducting an exploratory dig soon, Low Pressure Issues, 680 Wine Cellars (Swick Rd) and other water customers (Fayette Water District) on the main transmission line from the Seneca Falls Water Treatment Plant have been experiencing pressure issues, Fayette Water District will be checking all main line valves on transmission line to ensure they're in the open position and will also be conducting flow testing to help to determine if there's an issue, more information to follow
- ❖ Romulus Water District – met with parties involved with Amish water system, all information has been turned over to Pat Morrell for review, see attachment for list of all water services
- ❖ Romulus Sewer District – service call 5704 Main St, possibly clogged sewer main, checked sewer main and determine the issue was in the customer sewer lateral, turned over to customers plumber

Respectfully submitted,

Hobie Stapleton

Water Department Superintendent

Henry E Beiler

5918 Rt. 414 Romulus

Tax ID # 9-1-2.1

House, several cow barns, Greenhouse and working well

Jessie U Stoltzfus

5907 Rt 414 Romulus

Tax ID # 9-1-3.12

House, several barns and three greenhouses

Daniel B Esh

5839 Rt. 96 Romulus

Tax ID # 3-1-72

House, Cow barns and greenhouse and working well

Moses B Fisher

2139 Yerkes Rd Romulus

Tax ID # 9-1-2.2

House, Quilt shop, supply store and Greenhouse

Auction house

Stephen E Hertzler Tax ID # 9-1-4.111

Vineyard Road Auction LLC Tax ID # 9-1-4.112

Seneca Produce Auction LLC Tax ID # 9-1-4.12

2033 Yerkes Rd Romulus

Two bathrooms auction house, multiple yard hydrants ~~conserves watering trough~~ and multiple small food operations