

## ***Romulus Town Board Meeting***

### ***Water & Sewer District Reports***

**Date: October 19, 2022**

#### **To: Romulus Town Board**

- ❖ Willard Water District – September daily average – 16,000 gallons
- ❖ Romulus Water District – September daily average – 34,000 gallons
- ❖ Rt. 89 Water District – September daily average – 5,600 gallons
- ❖ Willard WTP Total – September daily average – 167,000 gallons
- ❖ Willard DTC Campus – September daily average – 148,000 gallons
- ❖ Water testing – currently all sample draws are up to date in all water districts
- ❖ NYSDOH monthly reports – September's DOH reports for all districts completed and sent to Seneca County Health Services
- ❖ U-DIG NY tickets – Regular tickets - 12    Emergency – 0
- ❖ Water meter readings – all water meter readings have been completed for the third quarter and bills have been sent out
- ❖ New water service request – 5677 Rt. 89, new house installation
- ❖ New Laborer Position – position was filled by Kevin Kaiser of Ovid
- ❖ Willard Water Treatment Plant – Elevated Tank VFD, waiting on Koester Associates to set up appointment, DVD water sample station – unit arrived today, will be setting up installation date , Chlorine Pacing System - is not working and has been out of service for some time, Aqua Logics will be working to get system up and running, Finished water transfer pump replacement - pump will be replaced by Koester Associates, waiting on installation date, Hach CL-17 chlorine analyzer – Aqua Logics replaced keyboard, unit is in good working order, Elevated THM issues in Willard WD – met with Seneca DOH, NYSDOH and Hunt's Engineers, per Hunt's recommendations, will be lowering finished tank level to 70% max, to allow quicker water turn over, WTP Heat and Backup power- DOCCS will be

restarting the central boiler plant on the Willard DTC grounds, restarting process could take up to 30 days, DOCCS has installed temporary heating unit to cover low temperatures during this time, the water treatment plant should be all set for heat and backup power for this heating season or until something else changes

- ❖ Assist Interlaken DPW – helped Interlaken (10/11/22) to replace curb stop on Mechanic Street
- ❖ Willard Water District – conducting on going flushing of the system
- ❖ Rt. 89 Water District – conducted surveillance THM's sample @ Rt. 89-meter house on 10/20/22, results were 85 parts per billion or 5 parts per billion above the allowable concentration
- ❖ Romulus Water District – Master Meter Co. reprogrammed Romulus master meter today, will be working with Aqua Logics to complete RTU installation

**Respectfully submitted,**

*Hobie*

**Hobie Stapleton**

**Water Department Superintendent**