

Romulus Town Board Meeting

Water & Sewer District Reports

Date: November 16, 2022

To: Romulus Town Board

- ❖ Willard Water District – October daily average – 27,800 gallons
- ❖ Romulus Water District – October daily average – 33,700 gallons
- ❖ Rt. 89 Water District – October daily average – 5,900 gallons
- ❖ Willard WTP Total – October daily average – 128,800 gallons
- ❖ Willard DTC Campus – October daily average – 100,600 gallons
- ❖ Water testing – currently all sample draws are up to date in all water districts
- ❖ NYSDOH monthly reports – October's DOH reports for all districts completed and sent to Seneca County Health Services
- ❖ U-DIG NY tickets – Regular tickets - 13 Emergency – 0
- ❖ Service Truck – oil change/rotate tires/multi-point inspection completed by Friendly Ford, clunk in front end, bad left tie rod end, Friendly Ford replaced tie rod end, covered under warranty
- ❖ Willard Water Treatment Plant – WTP Heat – steam heat is back on, Department of Health Inspection – was completed on November 1st, Filter #1 - flocculator motor stopped working, motor was replaced, Filter #1 is back in service
- ❖ Willard Water District – system flushing is complete for the season; all fire hydrants have been winterized
- ❖ Rt. 89 Water District – system flushing is complete for the season, leak on system – 5,400 gallons daily, found house leak, 5976 Rt 89, owner was notified
- ❖ Romulus Water District – system flushing is complete for the season; all fire hydrants have been winterized, fire hydrant @ 5631 Main Street is out of service, seven fire hydrants cleaned up and painted

Respectfully submitted,

Hobie

Hobie Stapleton

Water Department Superintendent