

# ***Romulus Town Board Meeting***

## ***Water & Sewer District Reports***

**Date: December 21, 2022**

**To: Romulus Town Board**

- ❖ Willard Water District – November daily average – 16,000 gallons
- ❖ Romulus Water District – November daily average – 57,000 gallons
- ❖ Rt. 89 Water District – November daily average – 5,900 gallons
- ❖ Willard WTP Total – November daily average – 133 ,000 gallons
- ❖ Willard DTC Campus – November daily average – 117,000 gallons
- ❖ Water testing – currently all sample draws are up to date in all water districts
- ❖ NYSDOH monthly reports – November’s DOH reports for all districts completed and sent to Seneca County Health Services
- ❖ U-DIG New York – updated 2023 holidays, tickets – Regular – 1 Emergency – 0
- ❖ Romulus Water District – water main leak 12-7-2022, 2070 Cayuga St, low PSI to 28 water services (Romulus and Varick Water Districts) for less than 3 hours, installed repair band, assisted by Town of Varick Water Department, Seneca Co. Highway and New York Rural Water Association. Big thanks to all.

**Respectfully submitted,**

*Hobie*

**Hobie Stapleton**

**Water Department Superintendent**