

Romulus Town Board Meeting

Water & Sewer District Reports

Date: February 15, 2023

To: Romulus Town Board

- ❖ Willard Water District – January daily average – 18,100 gallons
- ❖ Romulus Water District – January daily average – 40,900 gallons
- ❖ Rt. 89 Water District – January daily average – 4,400 gallons
- ❖ Willard WTP Total – January daily average – 121,700 gallons
- ❖ Willard DTC Campus – January daily average – 103,600 gallons
- ❖ Water testing – all sample draws are up to date in all water districts
- ❖ NYSDOH monthly reports – January’s DOH reports for all districts completed and sent to Seneca County Health Services
- ❖ U-DIG New York – tickets, Regular – 1 Emergency – 0
- ❖ Varick Water Department – assisted Varick with water service installation – Seneca Lake Water District
- ❖ Training – we attended training at Finger Lakes Water Works in Canandaigua
- ❖ Willard WTP/ Willard DTC – filter #2 Flocculator stopped working and gear box is leaking, main control rod was heavily rusted and seal leaking on gear box, filter #2 was taken out of service, DOCCS was notified and waiting for Koester Associates to quote a price for repair, installed new light bulbs on exterior security lights @ WTP and Lakeshore Pump House – currently all exterior security lights working, DOCCS contractor paired leaking heater unit in WTP electrical room – heater back in service, DOCCS contractor have repaired several water main leaks on facility grounds resulting in daily decrease of 64,000 gallons

Respectfully submitted,

Hobie

Hobie Stapleton

Water Department Superintendent