

Romulus Town Board Meeting

Romulus Water & Sewer District Reports

Date: June 21, 2023

To: Romulus Town Board

- ❖ Romulus Water District – April daily average – 38,900 gallons
- ❖ Willard Water District – April daily average – 17,300 gallons
- ❖ Rt. 89 Water District – April daily average – 4,800 gallons
- ❖ Willard WTP Total – April daily average – 88,400 gallons
- ❖ Willard DTC Campus – April daily average – 70,600 gallons
- ❖ Romulus Water District – May daily average – 45,100 gallons
- ❖ Willard Water District – May daily average – 24,700 gallons
- ❖ Rt. 89 Water District – May daily average – 9,800 gallons
- ❖ Willard WTP Total – May daily average – 109,400 gallons
- ❖ Willard DTC Campus – May daily average – 78,610 gallons
- ❖ Water testing - all sample draws have been collected and are up to date in all water districts.
- ❖ NYSDOH monthly reports – April's and May's DOH reports for all districts were completed and sent to Seneca County Health Services
- ❖ U-DIG New York – tickets, Regular – 5 Emergency – 1
- ❖ Water meter installation – 2, 1406 Prospect St. Willard and 2010 Cayuga St Romulus Fill Station (meter is under warranty)
- ❖ New water service inquiry – (Rt.89 W.D.) Susan & Frank Grosso 5878 Rt. 89 & 2848 Vineyard Rd.
- ❖ New water service installation – 1 6095 Poplar Beach Rd.
- ❖ Romulus Water District – 5/11 repaired large leak 5526 Rt. 96 T/Varick, 5/17 assist Varick W.D. with main line valve replacement 5614 Rt. 96 T/Varick, Seneca Co. Highway replaced driveway culvert @ 2070 Cayuga St., culvert was damaged during January water main leak
- ❖ Willard Water Treatment Plant – Filter#2 flocculator stopped working again, unit was temporarily repaired, Koester Associates here to evaluate unit for permanent repair, awaiting quote, elevated tank level was repaired and backwash meter reader was replaced by Aqua Logics, both are back in service, elevated pump #1 check valve is leaking, repair quote was sent to DOCCS Five Points for repair approval

- ❖ Willard Water District – 6/13 large leak 1481 Main St., installed 53” repair pipe
- ❖ Service call – 1, 6167 Poplar Beach Rd., high water usage, determined to be leaking toilet
- ❖ Annual Water Quality Report – All 2022 AWQR’s for all water districts is completed and approved by DOH, All AWQR’s for all water districts has been placed on the town web site and AWQR notifications will be mailed with upcoming billing cycle

Respectfully submitted,

Hobie Stapleton

Water Department Superintendent