

Romulus Town Board Meeting

Romulus Water & Sewer District Reports

Date: August 16, 2023

To: Romulus Town Board

- ❖ Romulus Water District – July daily average – 36,800 gallons
- ❖ Willard Water District – July daily average – 19,000 gallons
- ❖ Rt. 89 Water District – July daily average – 9,000 gallons
- ❖ Willard WTP Total – July daily average – 124,300 gallons
- ❖ Willard DTC Campus – July daily average – 111,400 gallons
- ❖ Water testing - all sample draws have been collected and are up to date in all water districts.
- ❖ NYSDOH monthly reports – July’s DOH reports for all districts were completed and sent to Seneca County Health Services
- ❖ U-DIG New York – tickets, Regular – 19 Emergency – 0
- ❖ New water service installation – 1 5895 Vineyard Rd Ext
- ❖ Water meter/register installation – 1 1392 Prospect Street Willard
- ❖ Service Truck – Wally’s Ford completed oil change and PM service
- ❖ New Service Truck was delivered to Van Bortel Ford, truck is at Unicell Truck Equipment for service body, snowplow and warning lights installation
- ❖ Willard Water Treatment Plant – Filter#2 flocculator, Koester Associates was here to evaluate filter unit for repair, quote was approved by DOCCS, waiting on work start date - working with OGS and Massa Construction on fire hydrant inventory and flushing - Finished water pump, Koester Is scheduled to be here Friday for final pump installation - chemical injection line leaking, line was repaired and pump is back in service - 5 backflow units needed annual testing, 3 units passed, 1 unit failed (repair parts on order), 1 unit is untestable (this unit will be repaired and tested by OGS contractors) - all water treatment plant piping was labeled with names and water flow direction - due to continued building break-ins and vandalism on the Willard facility grounds, cameras have been added to water treatment plant for security reasons

- ❖ Water system flushing – quarterly flushing was completed in all water districts
- ❖ Willard Water District Improvement Project – Main St and CR 132A water shut off valves have been located, Wenzel Contractors on location, improvement project started on August 15, staging area has been setup, spoils discharge area has been located, project information letter was sent to all Willard Water District customers, Main St. roadway cut is near completion, water pipe has been delivered

Respectfully submitted,
Hobie Stapleton
Water Department Superintendent