

***Romulus Town Board Meeting***  
***Romulus Water & Sewer District Reports***

**Date: September 20, 2023**

**To: Romulus Town Board**

- ❖ Romulus Water District – August daily average –36,200 gallons
- ❖ Willard Water District – August daily average – 33,700 gallons
- ❖ Rt. 89 Water District – August daily average – 10,400 gallons
- ❖ Willard WTP Total – August daily average – 143,600 gallons
- ❖ Willard DTC Campus – August daily average – 87,700 gallons
- ❖ Water testing - all sample draws have been collected and are up to date in all water districts.
- ❖ NYSDOH monthly reports – August’s DOH reports for all districts were completed and sent to Seneca County Health Services
- ❖ U-DIG New York – tickets, Regular – 6 Emergency –1
- ❖ New water service installation – 1 5905 Vineyard Rd Ext
- ❖ Willard Water Treatment Plant – Filter#3 is out of service, broken flocculator, Koester Associates is scheduled to repair next week
- ❖ Willard Water District Improvement Project – Main St. water pipe installation is complete, water service installation has started and will continue on Main St. until all services are switched over

**Respectfully submitted,**  
**Hobie Stapleton**  
**Water Department Superintendent**