

Romulus Town Board Meeting

Romulus Water & Sewer District Reports - Date: October 18, 2023

To: Romulus Town Board

- ❖ Romulus Water District – September daily average – 36,200 gallons
- ❖ Willard Water District – September daily average – 33,700 gallons
- ❖ Rt. 89 Water District – September daily average – 10,400 gallons
- ❖ Willard WTP Total – September daily average – 143,600 gallons
- ❖ Willard DTC Campus – September daily average – 87,700 gallons
- ❖ Water testing - all sample draws have been collected and are up to date in all water districts.
- ❖ NYSDOH monthly reports – September’s DOH reports for all districts were completed and sent to Seneca County Health Services
- ❖ U-DIG New York – tickets, Regular – 4 Emergency – 0
- ❖ Water meter reading – 3rd quarter meter readings have been completed in all districts and water bills have been sent out.
- ❖ Willard Water Treatment Plant – Filter#3 is out of service, broken flocculator, Koester Associates currently repairing unit, WTP comprehensive facilities assessment - met with Hunt Engineering team to go over all WTP and Lake Pump house issues – very good meeting, chemical pump stopped working - new pump head ordered and installed – pump back in service, 9/2 HAB’s starting on lake shore along facility grounds – raw water pump turned off and Seneca/State DOH notified, HAB’s on lakeshore for 9/3 & 9/4 - raw water intake pump shutdown, 9/5-9/6 no HAB’s detected on Lake Shore, 9/6 raw water intake back on @ 1PM, no other HAB’s detected,
- ❖ Willard Water District Improvement Project – Main St. roadway and driveway binder paving restoration is near completion ,Prospect St water main installation is complete, Prospect St. water main tie-in is scheduled for tomorrow, water will be off at 9 AM, estimated duration 1.5 hours not to exceed 3 hours, water service interruption notices (approximately 85 customers Main St, 2nd Street & Prospect Street – from Town Hall to dead end) were hand delivered to all-affected customers, Seneca County Highway started Main St. drainage project currently in the area of J&R’s old store

Respectfully submitted,

Hobie Stapleton, Water Department Superintendent