

# ***Romulus Town Board Meeting***

## ***Romulus Water & Sewer District Reports***

**Date: May 15, 2024**

### **To: Romulus Town Board**

- ❖ Romulus Water District – April’s daily average – 41,600 gallons
- ❖ Willard Water District – April’s daily average – 16,600 gallons
- ❖ Rt. 89 Water District – April’s daily average – 4,383 gallons
- ❖ Willard WTP Total – April’s daily average – 84,696 gallons
- ❖ Willard DTC Campus – April’s unaccounted daily average – approximately 30,000 gallons
- ❖ Water testing – all sample draws were collected and all draws are up to date in all districts.
- ❖ NYSDOH monthly reports – April’s DOH reports for all districts, were completed and sent to Seneca County Health Services
- ❖ U-DIG New York – total tickets = 3 / Regular – 3 / Emergency – 0
- ❖ Service trucks – 23 Ford is in service, 20 Ford repairs are completed, truck is back in service.
- ❖ Willard Water Treatment Plant – campus water system shutdown - Massa and OGS have shutdown the Birches/Hatch loop, Maples/Hadley Hall loop and currently working on the Elliot Hall/North home loop, OGS is having a locate company come in and assist with water line lay out on the lower end of campus, Elevated pump #1 - out of service, pump start-up has been authorized by OGS and should be scheduled very soon, WTP steam heat system – system has been removed from WTP
- ❖ Willard Water District Improvement Project – basement drain issues Main Street, Bill Church 1503 Main Street - Lagana Plumbing was here on 5/1/24 videoed basement drain line, line is damaged and full of rocks about 1 Foot from drain entrance, Tree removal 6970 Rt 96a – Finger Lakes Forest Management & Timber Harvesting removed tree, job looks great and owner is very satisfied with removal, 132a/96a Easements – all easements have been signed, Willard Water System Improvement Project – project will start up Monday May 20<sup>th</sup> – project will start with the 1<sup>st</sup> Street water main tie-in
- ❖ Romulus Water District – service line leak, old service line to Stivers TP, line was shut down at corporation valve on main, Romulus master meter totals have dropped some, Romulus and Varick WD’s will be doing comparison meter reading in a couple of weeks, more information to follow.
- ❖ Kevin’s Class D certification – received Class D – Distribution System Water Operator certificate, A BIG CONGRATULATIONS! to Kevin.

**Respectfully submitted,**

*Hobie*

**Hobie Stapleton**

**Water Department Superintendent**