

Romulus Town Board Meeting

Romulus Water & Sewer District Reports

Date: January 17, 2024

To: Romulus Town Board

- ❖ Romulus Water District – December’s daily average – 41,100 gallons
- ❖ Willard Water District – December’s daily average – 17,400 gallons
- ❖ Rt. 89 Water District – December’s daily average – 3,700 gallons
- ❖ Willard WTP Total – December’s daily average – 98,900 gallons
- ❖ Willard DTC Campus – December’s daily average – 71,800 gallons
- ❖ Willard DTC Campus – December’s unaccounted daily average – 29,500 gallons
- ❖ Water testing – all sample draws have been collected and are up to date in all districts. Willard W.D. THM’s (disinfection byproduct) annual running average has dropped below the New York State DOH’s maximum contamination level
- ❖ NYSDOH monthly reports – December’s DOH reports for all districts were completed and sent to Seneca County Health Services
- ❖ U-DIG New York – total tickets = 2 / Regular – 2 / Emergency – 0
- ❖ Water meter installation – 23 meter change out letters were distributed, 3 meters changed out – Mennonite School Cayuga St. Romulus, DeLong 6988 CR 132a & Hoffman 7036 Prospect St Willard, 11 meters are scheduled to be changed out, 2 have made contact and will schedule soon.
- ❖ Service call – 1 6187 Poplar Beach Spur Rd., no water, water near driveway - possible water main break, found no issues with water system, customer had stuck pressure regulating valve
- ❖ new service truck – no news, still waiting.
- ❖ Willard Water Treatment Plant – elevated pump #1 out of service, waiting for DOCCS to setup pump startup.
- ❖ Willard Water District Improvement Project – Wenzel finished new water main installation on C.R. 132 and completed water main tie-in at meter pit. Project has stopped for the winter season.

Respectfully submitted,

Hobie

Hobie Stapleton

Water Department Superintendent