

Romulus Town Board Meeting

Romulus Water & Sewer District Reports

Date: February 21, 2024

To: Romulus Town Board

- ❖ Romulus Water District – January’s daily average – 46,600 gallons
- ❖ Willard Water District – January’s daily average – 17,500 gallons
- ❖ Rt. 89 Water District – January’s daily average – 3,300 gallons
- ❖ Willard WTP Total – January’s daily average – 94,600 gallons
- ❖ Willard DTC Campus – January’s daily average – 77,100 gallons
- ❖ Willard DTC Campus – January’s unaccounted daily average – 30,900 gallons
- ❖ Water testing – received 2024 DOH’s sample schedule for all districts, all sample draws were collected and all draws are up to date in all districts.
- ❖ NYSDOH monthly reports – January’s DOH reports for all districts, were completed and sent to Seneca County Health Services
- ❖ U-DIG New York – total tickets = 4 / Regular – 4 / Emergency – 0
- ❖ Water meter change out – 14 meters, scheduled meter change out – 3, will be sending out new round of meter change notices soon.
- ❖ new service truck – no news
- ❖ Willard Water Treatment Plant – 2023 NYSDEC water withdrawal report was completed and submitted to DEC, filter #2 is out of service for backwash door replacement and flocculator repair, Massa Construction and Underground Locating Co. @ WTP, laying out new fence location for installation., Elevated pump #1 out of service, waiting for DOCCS to setup pump startup
- ❖ Willard Water District Improvement Project – basement drain issues after new water main was installed, Amity Chrisman 1499 Main St., Brewer’s Septic sent video camera in basement drain line, 6 feet from house, line appears to have fresh mud flowing inward to basement, Marty is familiar with drain lines and drain issues on Main Street, he believes line went to the south side of Main St., line is very old and most likely damaged during construction, spoke with Dave from Wenzel, will be here next week to repair line, Brewer’s will be here next week to clean line

Respectfully submitted,

Hobie

Hobie Stapleton, Water Department Superintendent