

Romulus Town Board Meeting

Romulus Water & Sewer District Reports

Date: April 17, 2024

To: Romulus Town Board

- ❖ Romulus Water District – March’s daily average – 41,700 gallons
- ❖ Willard Water District – March’s daily average – 16,000 gallons
- ❖ Rt. 89 Water District – March’s daily average – 3,658 gallons
- ❖ Willard WTP Total – March’s daily average – 98,740 gallons
- ❖ Willard DTC Campus – March’s unaccounted daily average – 30,000 gallons
- ❖ Water testing – all sample draws were collected and all draws are up to date in all districts.
- ❖ NYSDOH monthly reports – March’s DOH reports for all districts, were completed and sent to Seneca County Health Services
- ❖ U-DIG New York – total tickets = 15 / Regular – 15 / Emergency – 0
- ❖ Water meters – all meter readings were collected and bills have been sent out to customers for the 1st quarter
- ❖ Service trucks – 23 Ford is in service, 20 Ford needs some repairs - broken rear leaf spring, front tie rod replacement and needs brakes all the way round, truck going to Friendly Ford tomorrow.
- ❖ Willard Water Treatment Plant – 3/22/24 Bleak House shutdown, Massa construction damaged water service corporation stop at water main, unable to control water system to make quick repair, boil water advisory was issued at 7:30 PM for campus (affecting only DVD and WWTP), repair was completed around 11 PM, water sample draws were taken for two consecutive days, all samples were good, DOH lifted water boil advisory Monday 3/25/24. campus shut down, reviewed shut down plan with Hunts engineering, cutting and capping is on hold for now, must have closing plan for DOH, working with Seneca Co. DOH and NYSDOH Rochester office and OGS to create a shutdown plan for the campus water system to be approved by NYSDOH, met with Ovid Fire Chief Al Demming to go over shutdown plan, OFD is requesting to have all not in service fire hydrants to be bagged with HD black plastic bag, also going to add a not in service marker to the steamer connection. Filter #2 repair is completed and filter is back in service, WTP fence – driveway post was removed and opening was modified to fit driveway, fence installation is completed, Elevated pump #1 - out of service, waiting for DOCCS to setup pump startup, Filter media replacement and under drain inspection, met with Koester Associates to go over several

- items @ WTP to be repaired, received quotes for pump start up, filter media change, piping modifications to raw water tap and filter control panel, all quotes were sent to OGS
- ❖ Willard Water District Improvement Project – basement drain issues Main Street - Amity Chrisman 1499 Main St., Lagana Plumbing located basement drain line to new water main trench dig area, Wenzel repaired drain line, all works good, also working with Bill Church 1503 Main Street, with the same issue, Lagana Plumbing is schedule here on May 1. Tree removal 6970 Rt 96a – authorization paperwork is completed and tree is scheduled to be removed May 29th by Finger Lakes Forest Management & Timber Harvesting. 132a/96a Easements – 4 easements remained to be signed, made contact with Jay and VanEtten, both will be in next week to sign, unable to make contact with Steinhall and McDonald
 - ❖ Romulus Water District – waiting for response from Master Meter water meter company on the installation of Seneca Co master meter located on old depot.
 - ❖ Training – we attended OSHA 10 Hour Construction Safety and Health class in Seneca Falls, U Dig NY certified excavator program class in Penn Yan and Finger Lakes Water Works training in Canandaigua.
 - ❖ Kevin's Class D certification - all paperwork was submitted to Seneca County DOH, onsite assessment is scheduled for tomorrow.

Respectfully submitted,

Hobie

Hobie Stapleton
Water Department Superintendent